

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTINGS No. 3330-1246:103 Page 1 of 1

CATEGORY: Access Door (Fire-Rated)

LISTEE: *The William Brothers Corporation, 777 Tapscott Road, Scarborough, ONT Canada M1X 1A2
Contact: William G. Williams (416) 299-7767

DESIGN: Model WB-FR Standard fire rated ceiling access door. Frame of 18 Ga. steel and door of 16 Ga. steel, recessed pan construction with 1-7/8 in. mineral wool, fully concealed pivot type hinge and automatic closer. Assembly to be self-latching with flush key operated lock or raised knurled knob lock.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, WHI and UL Label.

APPROVAL: Listed as fire-rated access door for use in 1 hr. (for combustible) and 3 hr. (non-combustible) floor/ceiling assemblies up to 24" x 36" in size where access openings are permitted. Models with UL label are listed for access opening in masonry and drywall walls requiring 1-1/2 hour protection.

*Corrected 06-23-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 15, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager